



## MARICOPA COUNTY COMMUNITY COLLEGES

### INVITATION FOR BID IFB#2955-9 AMENDMENT #1

The following represent changes and clarifications to Invitation for Bid #2955-9. **Bidders are required to sign and submit this Amendment with all other required documents.** This Amendment shall become a part of any subsequent contract.

#### ACCEPTABLE SUBSTITUTES:

1. Atlas FAP42T-2043 speakers are an acceptable alternate to Tannoy.
2. Crown or Crestron amps that meet the same specs as the Extron are acceptable.

#### CHANGES/CLARIFICATIONS:

1. The Price List (Appendix A) reflects two separate quantities of 48 Tannoy speakers for the medium classrooms (Line MC3 & MC4). The correct quantity is 48 total.
2. The drawings depict all Crestron MPS devices as 70-volt. 70-volt models are only required in the medium classrooms. (Refer to line MC7 on Appendix A )
3. An “electronic copy” of Appendix A-r1.0 is available on request- [dmdllc@cox.net](mailto:dmdllc@cox.net)
4. The drawings depict a composite connection from the DVD/VCR- the connection is component. A composite run from the wall plate to the projector is still required.
5. The Lectern wall plate has changed to a 5-gang instead of a 4-gang.
6. The “Lecture” floor plate shall be used in the Ceramics Studio instead of the Lecture Room.
7. Cables for the Lecture Room shall terminate directly to the equipment via the floor box.
8. The “Ceramics Plasma” plate shall be **deleted**.
9. Covid, Inc. has master quote available for the wall plates. (Part numbers are on Appendix a-r1.0)

ALL OTHER TERMS AND CONDITIONS OF IFB #2955-9 REMAIN UNCHANGED AND ARE TO BE BID AS STATED.

COMPANY: \_\_\_\_\_ SIGNATURE: \_\_\_\_\_